

First fix Dis-assembly guide for MIX6500

1 Undo head retaining cap (A) by gripping between nails and unscrewing anti-clockwise. Place aside then unscrew wall plate (B) anti clock wise until free of body threads



2 Lift up wall plate (B) to expose temperature indicator band, mark band to body thread position with maker pen as (C) Now undo the head by unscrewing the phillips retaining screw inside the cap aperture A.



3 Lift off head and backplate and place safely to one side. Mark position of backstop band (E) to the valve cartridge as indicated in (D). Remove backstop and place aside. Protect cartridge head with appropriate size plastic bag and secure over cartridge head and valve body threads with masking tape to prevent plaster / debris contamination etc.



4 After second fix completed re-assemble unit ensuring you line up the back stop to the cartridge marking (D) and replace head using marking on temperature band and body threads as(C).

